



NOTES:

1. CONCRETE SHALL HAVE A MINIMUM ULTIMATE COMPRESSIVE STRENGTH AT 28 DAYS OF 2500 P.S.I. CONCRETE MAY BE PNEUMATICALLY PLACED AND SHALL CONFORM TO SECTION 2621 OF THE UNIFORM BUILDING CODE.
2. REINFORCING SHALL BE 6" x 6" - W1.4 x W1.4 WELDED WIRE MESH OR APPROVED EQUAL.
3. GROUND SHALL BE PRE-WETTED TO THE SATISFACTION OF THE CITY ENGINEER PRIOR TO PLACEMENT OF CONCRETE. CURING COMPOUND SHALL BE USED WHEN REQUIRED BY THE CITY ENGINEER.
4. ANCHORS SHALL BE CONSTRUCTED IN ACCORDANCE WITH STANDARD PLAN 439 SHEET 2 OF 3 WHEN SLOPE EQUALS OR EXCEEDS 2:1.

CITY OF MISSION VIEJO



INTERCEPTOR DRAIN

STANDARD
PLAN NO.

437

Robert Anderson 9-23-03
 APPROVED RCE 30190 DATE

SHT 1 OF 1